



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

H. R. Swift School

5 Swift Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

Date & Time First Draw Sampled: 06/15/2016 06:00 - 06:38

Date & Time Analyzed: 06/16/2016 16:06 - 18:01

Date & Time Analyzed: 06/17/2016 10:59 - 12:20

Sample Location	Lab ID	First Draw	Action Level
Room 23 Fountain	055614	3.61	15
Room 18 Fountain	055615	6.38	15
Room 17 Fountain	055616	<2.0	15
Kitchen Main Prep Sink	055617	<2.0	15
Kitchen Auxillary Prep Sink	055618	108.20	15
Copy Coffee Room	055619	4.40	15
Main Office Work Room	055620	3.08	15
Nurses Exam Sink	055621	2.73	15
Nurses Kitchen Sink	055622	3.01	15
Library Work Room	055623	<2.0	15
Room 11 Fountain - Left	055624	<2.0	15
Room 16 Fountain	055625	5.83	15
Room 26 Faculty Sink	055626	<2.0	15
Room 11 Fountain - Right	055627	<2.0	15
Room 65 Fountain	055628	7.36	15
Room 56 Fountain	055629	13.79	15
Room 63 Fountain	055630	3.51	15
Room 62 Fountain	055631	14.04	15
Room 57 Sink	055632	2.20	15
Room 64 Fountain	055633	10.39	15
Room 58 Fountain	055634	3.77	15



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

H. R. Swift School

5 Swift Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

(Continued)

Date & Time First Draw Sampled: 06/15/2016 06:00 - 06:38

Date & Time Analyzed: 06/16/2016 16:06 - 18:01

Date & Time Analyzed: 06/17/2016 10:59 - 12:20

Sample Location	Lab ID	First Draw	Action Level
Room 61 Fountain	O55635	3.72	15
Room 59 Fountain	O55636	6.37	15
Room 60 Fountain	O55637	5.85	15

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L

Signature

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Eagle Academy

3517 Bargaintown Road
Egg Harbor Twp, NJ 08234

Results of Lead Analysis


Date & Time First Draw Sampled: 06/15/2016 07:00 - 07:11

Date & Time Analyzed: 06/16/2016 14:13 - 14:42

Sample Location	Lab ID	First Draw	Action Level
Main - East Fountain - Left	O55598	5.51	15
Main - East Fountain - Right	O55599	2.54	15
2nd Floor Fountain - Left	O55600	<2.0	15
2nd Floor Fountain - Right	O55601	2.20	15
Kitchen Sink - Left	O55602	2.13	15
Kitchen Sink - Right	O55603	<2.0	15

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L



Signature



Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Egg Harbor Township High School

24 High School Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

Date & Time First Draw Sampled: 06/15/2016 05:05 - 05:50

Date & Time Analyzed: 06/20/2016 13:19 - 16:11

Date & Time Analyzed: 06/21/2016 11:31 - 17:12

Date & Time Analyzed: 06/23/2016 13:06 - 13:52

Sample Location	Lab ID	First Draw	Action Level
D111	O55695	2.27	15
D Hall Fountain	O55696	<2.0	15
C128 Sink	O55697	<2.0	15
C Wing Main Hall Fountain - Left	O55698	<2.0	15
C Wing Main Hall Fountain - Right	O55699	3.05	15
C105 Front Sink	O55700	<2.0	15
C105 Station 1 Sink	O55701	182.00	15
C105 Station 2 Sink	O55702	2.34	15
C105 Station 3 Sink	O55703	<2.0	15
C105 Station 4 Sink	O55704	3.00	15
C105 Station 5 Sink	O55705	3.27	15
C105 Station 6 Sink	O55706	7.59	15
Commons Fountain - Middle	O55707	2.17	15
Commons Fountain - Right	O55708	2.54	15
Bagel Shop	O55709	<2.0	15
Flower Shop	O55710	<2.0	15
YST Conference	O55711	6.79	15
Nurses Station	O55712	5.78	15
B-Main Fountain - Left	O55713	12.88	15
B-Main Fountain - Right	O55714	17.80	15
Commons Fountain - Left	O55715	<2.0	15



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Egg Harbor Township High School

24 High School Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

(Continued)

Date & Time First Draw Sampled: 06/15/2016 05:05 - 05:50

Date & Time Analyzed: 06/20/2016 13:19 - 16:11

Date & Time Analyzed: 06/21/2016 11:31 - 17:12

Date & Time Analyzed: 06/23/2016 13:06 - 13:52

Sample Location	Lab ID	First Draw	Action Level
A Wing Ticket Fountain - Left	O55716	<2.0	15
A Wing Ticket Fountain - Middle	O55717	<2.0	15
A Wing Ticket Fountain - Right	O55718	6.82	15
A120 Fountain	O55719	3.06	15
A107 Fountain	O55720	<2.0	15
A171 Fountain	O55721	<2.0	15
A Wing Trophy Fountain - Left	O55722	<2.0	15
A Wing Trophy Fountain - Right	O55723	<2.0	15
Auxillary Gym Fountain - Left	O55724	<2.0	15
Auxillary Gym Fountain - Right	O55725	<2.0	15
E Wing Womens Bathroom Fountain	O55726	<2.0	15
E Wing Mens Bathroom Fountain	O55727	<2.0	15
Ella Sink	O55728	<2.0	15
1st Floor Main Office F101	O55729	<2.0	15
1st Floor F Wing Fountain - Left	O55730	<2.0	15
1st Floor Restroom Fountain - Right	O55731	<2.0	15
1st Floor Band Room Sink	O55732	<2.0	15
1st Floor Teachers Lounge	O55733	<2.0	15
Lower Cafeteria Fountain 1 - Left	O55734	<2.0	15
Lower Cafeteria Fountain 1 - Right	O55735	<2.0	15
Lower Cafeteria Fountain 2 - Left	O55736	<2.0	15



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Egg Harbor Township High School

24 High School Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

(Continued)

Date & Time First Draw Sampled: 06/15/2016 05:05 - 05:50

Date & Time Analyzed: 06/20/2016 13:19 - 16:11

Date & Time Analyzed: 06/21/2016 11:31 - 17:12

Date & Time Analyzed: 06/23/2016 13:06 - 13:52

Sample Location	Lab ID	First Draw	Action Level
Middle Cafeteria Fountain - Left	O55737	<2.0	15
Middle Cafeteria Fountain - Right	O55738	<2.0	15
Upper Cafeteria Fountain - Left	O55739	<2.0	15
Upper Cafeteria Fountain - Right	O55740	<2.0	15
Upper Kitchen Sink	O55741	2.59	15
Lower Kitchen Sink	O55742	<2.0	15
2nd Floor Library RR Fountain - Left	O55743	<2.0	15
2nd Floor Library RR Fountain - Right	O55744	<2.0	15
Main Library Back Sink	O55745	6.57	15
2nd Floor F Wing Mens Fountain - Left	O55746	<2.0	15
2nd Floor F Wing Mens Fountain-Right	O55747	<2.0	15
Library Breakroom Sink	O55748	<2.0	15



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Egg Harbor Township High School

24 High School Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

(Continued)


Date & Time First Draw Sampled: 06/15/2016 05:00 - 05:15

Date & Time Analyzed: 06/16/2016 14:47 - 15:54

Sample Location	Lab ID	First Draw	Action Level
D216 - Faculty Room	O55604	<2.0	15
D Wing 2nd Womens Fountain - Left	O55605	<2.0	15
D Wing 2nd Womens Fountain - Right	O55606	<2.0	15
C Wing C223 Fountain - Left	O55607	3.67	15
C Wing C223 Fountain - Right	O55608	2.95	15
B Wing Cross 201 Fountain - Left	O55609	7.30	15
B Wing Cross 201 Fountain - Right	No Sample Collected		
A Wing Restroom Fountain - Left	O55610	<2.0	15
A Wing Restroom Fountain - Right	O55611	3.58	15
E Wing 2nd Fountain - Left	O55612	<2.0	15
E Wing 2nd Fountain - Right	O55613	<2.0	15

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L


Signature


Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

C. J. Davenport Primary School

2499 Spruce Avenue
Egg Harbor Twp, NJ 08234

Results of Lead Analysis


Date & Time First Draw Sampled: 06/15/2016 05:37 - 05:52


Date & Time Analyzed: 06/17/2016 12:26 - 14:22

Sample Location	Lab ID	First Draw	Action Level
Cafeteria Fountain - Left	O55638	<2.0	15
Cafeteria Fountain - Right	O55639	<2.0	15
Kitchen Tap - Left	O55640	5.06	15
Kitchen Tap - Right	O55641	7.09	15
Kitchen Pot Sink - Right	O55642	6.30	15
Kitchen Pot Sink - Left	O55643	4.03	15
Nurse Station Fountain	O55644	<2.0	15
Nmain Office Kitchen Fountain	O55645	<2.0	15
Gym Fountain - Left	O55646	<2.0	15
Gym Fountain - Right	O55647	<2.0	15
D Wing Fountain - Left	O55648	<2.0	15
D Wing Fountain - Right	O55649	<2.0	15
A110 Faculty Room	O55650	<2.0	15
District Office	O55651	<2.0	15

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L


Signature


Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

C. J. Davenport Elementary School

2301 Spruce Avenue
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

Date & Time First Draw Sampled: 06/15/2016 05:55 - 06:08

Date & Time Analyzed: 06/17/2016 14:28 - 15:39

Sample Location	Lab ID	First Draw	Action Level
Gym - Right	O55652	10.84	15
Gym - Left	O55653	30.18	15
Cafeteria Hall Fountain - Far Left	O55654	12.55	15
Cafeteria Hall Fountain - Mid Left	O55655	12.71	15
Cafeteria Hall Fountain - Mid Right	O55656	<2.0	15
Cafeteria Hall Fountain - Far Right	O55657	<2.0	15
Food Prep - Left	O55658	35.35	15
Food Prep - Right	O55659	11.45	15
2nd Grade Fountain	O55660	<2.0	15
3rd Grade Fountain	O55661	<2.0	15

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L

Signature

7/6/16

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Slaybaugh Elementary School

11 Swift Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

Date & Time First Draw Sampled: 06/15/2016 06:02 - 06:28

Date & Time Analyzed: 06/17/2016 15:45 - 17:31

Date & Time Analyzed: 06/20/2016 12:33 - 13:13

Sample Location	Lab ID	First Draw	Action Level
Main Office Fountain - Right	O55662	<2.0	15
Library Kitchen Sink	O55663	4.58	15
Nurse Room Sink	O55664	<2.0	15
Nurse Bathroom	O55665	2.28	15
Room 22 Outside Fountain	O55666	<2.0	15
Room 24 Fountain	O55667	<2.0	15
Annex Fountain - Left	O55668	<2.0	15
Annex Fountain - Right	O55669	<2.0	15
Across Room 28 Fountain	O55670	<2.0	15
Across Room 30 Fountain	O55671	2.36	15
Teachers Lounge Sink	O55672	<2.0	15
Room 20 Fountain	O55673	<2.0	15
Room 7 Fountain	O55674	<2.0	15
Room 15 Fountain	O55675	2.35	15
Room 10 Sink	O55676	6.73	15
Across Cafeteria Fountain - Left	O55677	<2.0	15
Across Cafeteria Fountain - Right	O55678	<2.0	15
Kitchen Island Sink	O55679	4.73	15



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Slaybaugh Elementary School

11 Swift Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

(Continued)

Date & Time First Draw Sampled: 06/15/2016 06:02 - 06:28


Date & Time Analyzed: 06/17/2016 15:45 - 17:31

Date & Time Analyzed: 06/20/2016 12:33 - 13:13

Sample Location	Lab ID	First Draw	Action Level
Room 13 Fountain	O55680	<2.0	15
Room 12 Fountain	O55681	<2.0	15
Art Room Front Sink - Right	O55682	9.63	15
Art Room Front Sink - Left	O55683	4.90	15

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L



Signature

7/6/16

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Slaybaugh Primary School

13 Swift Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis


Date & Time First Draw Sampled: 06/15/2016 06:30 - 06:52

Date & Time Analyzed: 06/20/2016 13:19 - 14:31

Sample Location	Lab ID	First Draw	Action Level
Board Room Fountain	O55684	15.47	15
Cafeteria Fountain - Left	O55685	<2.0	15
Cafeteria Fountain - Right	O55686	<2.0	15
Kitchen Back Double Sink - Left	O55687	<2.0	15
Nurse Room Fountain	O55688	<2.0	15
Main Office Fountain	O55689	2.67	15
Gym Fountain - Left	O55690	<2.0	15
Gym Fountain - Right	O55691	<2.0	15
Across Faculty Fountain - Left	O55692	<2.0	15
Across Faculty Fountain - Middle	O55693	<2.0	15
Across Faculty Fountain - Right	O55694	<2.0	15

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L



Signature



Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Dr. Joyanne D. Miller Elementary School

2 Alder Avenue
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

Date & Time First Draw Sampled: 06/16/2016 05:55 - 06:51

Date & Time Analyzed: 06/23/2016 13:57 - 18:15

Sample Location	Lab ID	First Draw	Action Level
B107	O55803	9.00	15
D100 Fountain - Left	O55804	<2.0	15
D100 Fountain - Right	O55805	<2.0	15
D107	O55806	22.68	15
E139 Fountain - Left	O55807	<2.0	15
E139 Fountain - Right	O55808	<2.0	15
E130 Fountain - Left	O55809	<2.0	15
E130 Fountain - Right	O55810	<2.0	15
A100 Fountain - Left	O55811	<2.0	15
A100 Fountain - Right	O55812	<2.0	15
D207	O55813	30.49	15
E214	O55814	10.48	15
C200 Fountain - Left	O55815	<2.0	15
C210	O55816	21.49	15
E207	O55817	13.65	15
A200 Fountain - Left	O55818	<2.0	15
A210	O55819	26.92	15
B207	O55820	24.70	15
A200 Fountain - Right	O55821	<2.0	15
B200 Fountina - Left	O55822	<2.0	15
A110	O55823	21.29	15



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwater test.com
NJ DEP Certified Lab #08006

Dr. Joyanne D. Miller Elementary School

2 Alder Avenue
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

(Continued)


Date & Time First Draw Sampled: 06/16/2016 05:55 - 06:51

Date & Time Analyzed: 06/23/2016 13:57 - 18:15

Sample Location	Lab ID	First Draw	Action Level
E102	O55824	15.85	15
Nurse Sink	O55825	6.45	15
E118	O55826	10.17	15
C100 Fountain - Left	O55827	<2.0	15
C100 Fountain - Right	O55828	<2.0	15
C110	O55829	5.46	15
D200 Fountain - Left	O55830	<2.0	15
D200 Fountain - Right	O55831	<2.0	15
C200 Fountain - Right	O55832	<2.0	15
B200 Fountain - Right	O55833	<2.0	15
Kitchen Prep Sink Kettle	O55834	<2.0	15
Kitchen Prep Sink Warmers	O55835	<2.0	15
B100 Fountain - Left	O55836	<2.0	15
B100 Fountain - Right	O55837	<2.0	15

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L



Signature



Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Alder Avenue Middle School

25 Alder Avenue
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

Date & Time First Draw Sampled: 06/16/2016 05:00 - 05:43

Date & Time Analyzed: 06/24/2016 10:47 - 15:47

Sample Location	Lab ID	First Draw	Action Level
Main Office	O55838	2.95	15
Board Conference Room Kitchen	O55839	8.21	15
Nurses Sink	O55840	2.97	15
A121 Fountain	O55841	3.58	15
Kitchen Prep	O55842	2.84	15
Kitchen Main Steamer	O55843	11.34	15
Gym Hall Fountain - Left	O55844	<2.0	15
Gym Hall Fountain - Right	O55845	<2.0	15
Commons Fountain - Left	O55846	<2.0	15
Commons Fountain - Right	O55847	<2.0	15
Front Lobby Fountain	O55848	<2.0	15
B100 Fountain - Left	O55849	<2.0	15
B100 Fountain - Right	O55850	<2.0	15
B100 Sink	O55851	3.98	15
C121 Fountain - Left	O55852	<2.0	15
C121 Fountain - Right	O55853	<2.0	15
Library Work Room	O55854	<2.0	15
D102 Fountain - Left	O55855	<2.0	15
D102 Fountain - Right	O55856	<2.0	15
D113 Fountain - Left	O55857	<2.0	15
D113 Fountain - Right	O55858	<2.0	15
Music Hallway Fountain - Left	O55859	<2.0	15
Music Hallway Fountain - Right	O55860	<2.0	15
B212 Work Room	O55861	7.76	15



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Alder Avenue Middle School

25 Alder Avenue
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

(Continued)


Date & Time First Draw Sampled: 06/16/2016 05:00 - 05:43

Date & Time Analyzed: 06/24/2016 10:47 - 15:47

Sample Location	Lab ID	First Draw	Action Level
B206 Sink - Left	O55862	11.57	15
B206 Sink - Right	O55863	4.50	15
B221 Sink	O55864	9.46	15
B230 Fountain - Left	O55865	<2.0	15
B230 Fountain - Right	O55866	<2.0	15
B230 Sink	O55867	<2.0	15
Fountain - Left	O55868	<2.0	15
Fountain - Right	O55869	<2.0	15
C219 Fountain - Left	O55870	<2.0	15
C219 Fountain - Right	O55871	<2.0	15
D202 Fountain - Left	O55872	<2.0	15
D202 Fountain - Right	O55873	<2.0	15
D212 Fountain - Left	O55874	<2.0	15
D212 Fountain - Right	O55875	<2.0	15

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L



Signature



Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Fernwood Avenue Middle School

4034 Fernwood Avenue
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

Date & Time First Draw Sampled: 06/16/2016 04:58 - 05:52

Date & Time Analyzed: 06/24/2016 15:52 - 15:58

Date & Time Analyzed: 06/27/2016 14:29 - 17:50

Date & Time Analyzed: 06/28/2016 10:25 - 13:40

Sample Location	Lab ID	First Draw	Action Level
Auditorium Fountain - Left	O55876	<2.0	15
Auditorium Fountain - Right	O55877	<2.0	15
1st B1 Main Hall Fountain - Left	O55878	<2.0	15
1st B1 Main Hall Fountain - Right	O55879	<2.0	15
B114 Tap	O55880	<2.0	15
B115 Fountain - Left	O55881	<2.0	15
B115 Fountain - Right	O55882	<2.0	15
Across B119 Fountain - Left	O55883	<2.0	15
Across B119 Fountain - Right	O55884	<2.0	15
B120 Tap	O55885	3.49	15
Across Cafeteria Burger Pod - Left	O55886	6.21	15
Across Cafeteria Burger Pod - Right	O55887	<2.0	15
Across Cafeteria Silver Pod - Left	O55888	2.22	15
Across Cafeteria Silver Pod - Right	O55889	<2.0	15
Kitchen Right Sink Tap - Right	O55890	12.88	15
Kitchen Left Sink Tap - Left	O55891	3.70	15
Kitchen Left Sink Tap - Right	O55892	5.94	15
Nurse Office	O55893	3.15	15
Across D132 Fountain - Right	O55894	5.25	15
Gym - Left	O55895	<2.0	15



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Fernwood Avenue Middle School

4034 Fernwood Avenue
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

(Continued)

Date & Time First Draw Sampled: 06/16/2016 04:58 - 05:52

Date & Time Analyzed: 06/24/2016 15:52 - 15:58

Date & Time Analyzed: 06/27/2016 14:29 - 17:50

Date & Time Analyzed: 06/28/2016 10:25 - 13:40

Sample Location	Lab ID	First Draw	Action Level
Gym - Right	O55896	<2.0	15
D120 Fountain	O55897	4.58	15
Across D119 - Left	O55898	<2.0	15
Across D119 - Right	O55899	<2.0	15
Outside D115 Fountain - Left	O55900	2.90	15
Outside D115 Fountain - Right	O55901	<2.0	15
D114 Tap	O55902	<2.0	15
Across B233 Fountain - Left	O55903	<2.0	15
Across B233 Fountain - Right	O55904	2.62	15
B220 Tap	O55905	2.34	15
Across B219 Fountain - Left	O55906	2.87	15
B214 Tap	O55907	<2.0	15
Outside B2 Gang Bathroom - Left	O55908	2.86	15
Outside B2 Gang Bathroom - Right	O55909	<2.0	15
Across D236 Fountain - Left	O55910	<2.0	15
Across D236 Fountain - Right	O55911	4.84	15
Outside D2 Gang Bathroom - Left	O55912	4.99	15
Outside D2 Gang Bathroom - Right	O55913	2.56	15
D220 Tap	O55914	2.98	15
Across D219 Fountain - Left	O55915	<2.0	15
Across D219 Fountain - Right	O55916	5.98	15



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Fernwood Avenue Middle School

4034 Fernwood Avenue
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

(Continued)

Date & Time First Draw Sampled: 06/16/2016 04:58 - 05:52

Date & Time Analyzed: 06/24/2016 15:52 - 15:58


Date & Time Analyzed: 06/27/2016 14:29 - 17:50

Date & Time Analyzed: 06/28/2016 10:25 - 13:40

Sample Location	Lab ID	First Draw	Action Level
Outside D215 Fountain - Left	O55917	<2.0	15
Outside D215 Fountain - Right	O55918	4.42	15
D214 Tap	O55919	<2.0	15

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L



Signature



Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Slaybaugh Primary School

13 Swift Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

Date & Time First Draw Sampled: 08/03/2016 09:30

Date & Time Flushed Sampled: 08/03/2016 09:31

Date & Time Analyzed: 08/05/2016 12:44 - 12:50

Sample Location	First Draw	Action Level	Flushed	Action Level
Board Room Fountain	12.03	15	2.06	5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L

Signature

8/18/16

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax



www.sjwater.test.com
NJ DEP Certified Lab #08006

H. R. Swift School

5 Swift Drive
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

Date & Time First Draw Sampled: 08/03/2016 09:25

Date & Time Flushed Sampled: 08/03/2016 09:26

Date & Time Analyzed: 08/05/2016 12:56 - 13:02

Sample Location	First Draw	Action Level	Flushed	Action Level
Kitchen Auxillary Prep Sink	48.99	15	3.12	5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L

Signature

Date



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Dr. Joyanne D. Miller Elementary School

2 Alder Avenue
Egg Harbor Twp, NJ 08234

Results of Lead Analysis

Date & Time First Draw Sampled: 08/03/2016 10:30 - 11:50

Date & Time Flushed Sampled: 08/03/2016 10:31 - 11:51

Date & Time Analyzed: 08/05/2016 13:07 - 15:10

Sample Location	First Draw	Action Level	Flushed	Action Level
A110	25.79	15	<2.0	5
E102	11.62	15	<2.0	5
D107	48.05	15	<2.0	5
C210	27.42	15	<2.0	5
D207	15.82	15	<2.0	5
B207	28.74	15	3.02	5
A210	23.28	15	<2.0	5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary. NJDEP First Draw = 15 ug/L, Flushed = 5 ug/L

Signature

8/10/16

Date