



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Nathanael Roberts
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

6/20/2022

Phone: (856) 840-8800
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/2/2022. The results are tabulated on the attached data pages for the following client designated project:

22-411 Egg Harbor - High School

The reference number for these samples is EMSL Order #012208791. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208791
 CustomerID: TTIE54
 CustomerPO: 034933
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 0 / Field Blank **Collected:** 6/2/2022 **Lab ID:** 012208791-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:12

Client Sample Description 1 / EHS-WC-HA181-1 / By A-181 **Collected:** 6/2/2022 4:03:00 AM **Lab ID:** 012208791-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:19

Client Sample Description 2 / EHS-WC-HA181-2 / By A-181 **Collected:** 6/2/2022 4:03:00 AM **Lab ID:** 012208791-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:21

Client Sample Description 3 / EHS-SF-A195-3 / A-195 **Collected:** 6/2/2022 4:04:00 AM **Lab ID:** 012208791-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.18	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:22

Client Sample Description 4 / EHS-IM-A195-4 / A-195 **Collected:** 6/2/2022 4:05:00 AM **Lab ID:** 012208791-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:24

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012208791

CustomerID: TTIE54

CustomerPO: 034933

ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 5 / EHS-WF-A193-5 / A-193 Aux Gym **Collected:** 6/2/2022 4:07:00 AM **Lab ID:** 012208791-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:26

Client Sample Description 6 / EHS-WF-A193-6 / A-193 Aux Gym **Collected:** 6/2/2022 4:08:00 AM **Lab ID:** 012208791-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:27

Client Sample Description 8 / EHS-WC-GLOC-8 / Girls Locker **Collected:** 6/2/2022 4:10:00 AM **Lab ID:** 012208791-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.68	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:29

Client Sample Description 9 / EHS-WC-POOL-9 / Pool **Collected:** 6/2/2022 4:12:00 AM **Lab ID:** 012208791-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:30

Client Sample Description 10 / EHS-WC-POOL-10 / Pool **Collected:** 6/2/2022 4:12:00 AM **Lab ID:** 012208791-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:32

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208791
 CustomerID: TTIE54
 CustomerPO: 034933
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 11 / EHS-BF-POOL-11 / Pool **Collected:** 6/2/2022 4:13:00 AM **Lab ID:** 012208791-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:36

Client Sample Description 12 / EHS-WC-GYMRR-12 / Restroom By Gym **Collected:** 6/2/2022 4:15:00 AM **Lab ID:** 012208791-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:41

Client Sample Description 13 / EHS-BF-GYMRR-13 / Restroom By Gym **Collected:** 6/2/2022 4:16:00 AM **Lab ID:** 012208791-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:43

Client Sample Description 14 / EHS-WC-GYMRR-14 / Restroom By Gym **Collected:** 6/2/2022 4:16:00 AM **Lab ID:** 012208791-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.92	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:44

Client Sample Description 16 / EHS-WC-NSE-16 / Nurse B 130 **Collected:** 6/2/2022 4:20:00 AM **Lab ID:** 012208791-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.73	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:46

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208791
 CustomerID: TTIE54
 CustomerPO: 034933
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 17 / EHS-SF-NSE-17 / Nurse B 130 **Collected:** 6/2/2022 4:21:00 AM **Lab ID:** 012208791-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:47

Client Sample Description 18 / EHS-SF-NER-18 / Exam Room B-130 **Collected:** 6/2/2022 4:22:00 AM **Lab ID:** 012208791-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:49

Client Sample Description 19 / EHS-SF-CST-19 / Cst Office **Collected:** 6/2/2022 4:26:00 AM **Lab ID:** 012208791-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.35	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:50

Client Sample Description 20 / EHS-WC-COMM-20 / Common Area **Collected:** 6/2/2022 4:28:00 AM **Lab ID:** 012208791-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:55

Client Sample Description 21 / EHS-WC-COMM-21 / Common Area **Collected:** 6/2/2022 4:29:00 AM **Lab ID:** 012208791-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 09:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012208791

CustomerID: TTIE54

CustomerPO: 034933

ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 22 / EHS-BF-COMM-22 / Common Area **Collected:** 6/2/2022 4:29:00 AM **Lab ID:** 012208791-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:03

Client Sample Description 23 / EHS-WC-COMM-23 / Common Area **Collected:** 6/2/2022 4:29:00 AM **Lab ID:** 012208791-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.4	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:08

Client Sample Description 24 / EHS-SF-FAC-24 / Faculty Lounge **Collected:** 6/2/2022 4:33:00 AM **Lab ID:** 012208791-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:09

Client Sample Description 25 / EHS-SF-F101C-25 / F-101c **Collected:** 6/2/2022 4:35:00 AM **Lab ID:** 012208791-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.49	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:14

Client Sample Description 26 / EHS-WC-HF118-26 / Adj To F118 **Collected:** 6/2/2022 4:37:00 AM **Lab ID:** 012208791-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208791
 CustomerID: TTIE54
 CustomerPO: 034933
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 27 / EHS-WC-HF118-27 / Adj To F118 **Collected:** 6/2/2022 4:37:00 AM **Lab ID:** 012208791-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:17

Client Sample Description 28 / EHS-WC-FCUP-28 / Food Court Upper **Collected:** 6/2/2022 4:40:00 AM **Lab ID:** 012208791-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:19

Client Sample Description 29 / EHS-WC-FCUP-29 / Food Court Upper **Collected:** 6/2/2022 4:41:00 AM **Lab ID:** 012208791-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:20

Client Sample Description 30 / EHS-WC-FCMID-30 / Food Court Middle **Collected:** 6/2/2022 4:42:00 AM **Lab ID:** 012208791-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:22

Client Sample Description 31 / EHS-WC-FCMID-31 / Food Court Middle **Collected:** 6/2/2022 4:42:00 AM **Lab ID:** 012208791-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012208791

CustomerID: TTIE54

CustomerPO: 034933

ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 32 / EHS-WC-FCLCAF-32 / Food Court Lower By Cafe
Collected: 6/2/2022 4:44:00 AM
Lab ID: 012208791-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:25
-------	------	----	-----------	--------------	-----------------------

Client Sample Description 33 / EHS-WC-FCLCAF-33 / Food Court Lower By Cafe
Collected: 6/2/2022 4:45:00 AM
Lab ID: 012208791-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:33
-------	------	----	-----------	--------------	-----------------------

Client Sample Description 34 / EHS-WC-FCL-34 / Food Court Lower
Collected: 6/2/2022 4:47:00 AM
Lab ID: 012208791-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:34
-------	------	----	-----------	--------------	-----------------------

Client Sample Description 35 / EHS-WC-FCL-35 / Food Court Lower
Collected: 6/2/2022 4:48:00 AM
Lab ID: 012208791-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:36
-------	------	----	-----------	--------------	-----------------------

Client Sample Description 36 / EHS-SF-LOWKIT-36 / Lower Kitchen
Collected: 6/2/2022 4:50:00 AM
Lab ID: 012208791-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.40	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:37
-------	------	------	-----------	--------------	-----------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208791
 CustomerID: TTIE54
 CustomerPO: 034933
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 37 / EHS-SF-LOWKIT-37 / Lower Kitchen **Collected:** 6/2/2022 4:51:00 AM **Lab ID:** 012208791-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.34	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:39

Client Sample Description 38 / EHS-SF-LOWKIT-38 / Lower Kitchen **Collected:** 6/2/2022 4:52:00 AM **Lab ID:** 012208791-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:40

Client Sample Description 39 / EHS-SF-LOWKIT-39 / Lower Kitchen (2 Tub) **Collected:** 6/2/2022 4:53:00 AM **Lab ID:** 012208791-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:42

Client Sample Description 40 / EHS-SF-UPKIT-40 / Upper Kitchen **Collected:** 6/2/2022 4:55:00 AM **Lab ID:** 012208791-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.19	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:43

Client Sample Description 41 / EHS-PF-UPKIT-41 / Upper Kitchen **Collected:** 6/2/2022 4:56:00 AM **Lab ID:** 012208791-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/16/2022 VD	6/17/2022 VD 10:45

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208791
 CustomerID: TTIE54
 CustomerPO: 034933
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 42 / EHS-TK-UPKIT-42 / Upper Kitchen **Collected:** 6/2/2022 4:56:00 AM **Lab ID:** 012208791-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	35.8	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:13

Client Sample Description 43 / EHS-IM-UPKIT-43 / Upper Kitchen **Collected:** 6/2/2022 4:57:00 AM **Lab ID:** 012208791-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:18

Client Sample Description 44 / EHS-SF-BAG-44 / Bagel Shop **Collected:** 6/2/2022 4:59:00 AM **Lab ID:** 012208791-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:19

Client Sample Description 47 / EHS-WC-HE103-47 / Adj. E103 Storage **Collected:** 6/2/2022 5:01:00 AM **Lab ID:** 012208791-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:24

Client Sample Description 48 / EHS-WC-HE101-48 / Adj. E101 **Collected:** 6/2/2022 5:03:00 AM **Lab ID:** 012208791-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012208791

CustomerID: TTIE54

CustomerPO: 034933

ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 49 / EHS-SF-E119-49 / Room E-119 **Collected:** 6/2/2022 5:06:00 AM **Lab ID:** 012208791-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:27

Client Sample Description 50 / EHS-SF-C105-50 / C-105 Home Ec **Collected:** 6/2/2022 5:09:00 AM **Lab ID:** 012208791-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.57	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:29

Client Sample Description 51 / EHS-SF-C105-51 / C-105 Home Ec **Collected:** 6/2/2022 5:10:00 AM **Lab ID:** 012208791-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.30	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:30

Client Sample Description 52 / EHS-SF-C105-52 / C-105 Home Ec **Collected:** 6/2/2022 5:10:00 AM **Lab ID:** 012208791-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.29	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:32

Client Sample Description 53 / EHS-SF-C105-53 / C-105 Home Ec **Collected:** 6/2/2022 5:10:00 AM **Lab ID:** 012208791-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.9	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:33

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208791
 CustomerID: TTIE54
 CustomerPO: 034933
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 54 / EHS-SF-C105-54 / C-105 Home Ec **Collected:** 6/2/2022 5:11:00 AM **Lab ID:** 012208791-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.13	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:35

Client Sample Description 55 / EHS-SF-C105-55 / C-105 Home Ec **Collected:** 6/2/2022 5:11:00 AM **Lab ID:** 012208791-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.08	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:43

Client Sample Description 56 / EHS-SF-C105-56 / C-105 Home Ec **Collected:** 6/2/2022 5:11:00 AM **Lab ID:** 012208791-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.70	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:44

Client Sample Description 57 / EHS-WC-HC128-57 / Adj. C-128 **Collected:** 6/2/2022 5:14:00 AM **Lab ID:** 012208791-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.17	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:46

Client Sample Description 58 / EHS-WC-HC128-58 / Adj. C-128 **Collected:** 6/2/2022 5:14:00 AM **Lab ID:** 012208791-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.99	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:47

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208791
 CustomerID: TTIE54
 CustomerPO: 034933
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 59 / EHS-WC-HC128-59 / Behind C-128 **Collected:** 6/2/2022 5:15:00 AM **Lab ID:** 012208791-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.40	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:49

Client Sample Description 61 / EHS-SF-BRCOM-61 / Bridge Common Room **Collected:** 6/2/2022 5:19:00 AM **Lab ID:** 012208791-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:50

Client Sample Description 62 / EHS-SF-D107B-62 / D107b **Collected:** 6/2/2022 5:20:00 AM **Lab ID:** 012208791-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.60	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:52

Client Sample Description 63 / EHS-WC-D216-63 / D-216 Lounge **Collected:** 6/2/2022 5:22:00 AM **Lab ID:** 012208791-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.45	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:54

Client Sample Description 65 / EHS-WC-HD201-65 / Across D-201 **Collected:** 6/2/2022 5:25:00 AM **Lab ID:** 012208791-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 19:55

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208791
 CustomerID: TTIE54
 CustomerPO: 034933
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 66 / EHS-BF-HD201-66 / Across D-201 **Collected:** 6/2/2022 5:26:00 AM **Lab ID:** 012208791-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:04

Client Sample Description 67 / EHS-WC-HC223-67 / Adj C-223 **Collected:** 6/2/2022 5:27:00 AM **Lab ID:** 012208791-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.59	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:09

Client Sample Description 68 / EHS-WC-HC223-68 / Adj C-223 **Collected:** 6/2/2022 5:28:00 AM **Lab ID:** 012208791-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.31	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:11

Client Sample Description 69 / EHS-WC-HE201-69 / Adj E-201 **Collected:** 6/2/2022 5:30:00 AM **Lab ID:** 012208791-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:12

Client Sample Description 70 / EHS-WC-HE203-70 / Adj E-203 **Collected:** 6/2/2022 5:31:00 AM **Lab ID:** 012208791-0065

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:14

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208791
 CustomerID: TTIE54
 CustomerPO: 034933
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 71 / EHS-WC-HB201-71 / Adj B-201 **Collected:** 6/2/2022 5:33:00 AM **Lab ID:** 012208791-0066

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.56	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:15

Client Sample Description 72 / EHS-WC-HB201-72 / Adj B-201 **Collected:** 6/2/2022 5:34:00 AM **Lab ID:** 012208791-0067

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:20

Client Sample Description 73 / EHS-BF-HB203-73 / Adj B-203 **Collected:** 6/2/2022 5:36:00 AM **Lab ID:** 012208791-0068

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:22

Client Sample Description 74 / EHS-WC-HA223-74 / Adj B-223 **Collected:** 6/2/2022 5:39:00 AM **Lab ID:** 012208791-0069

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.09	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:23

Client Sample Description 75 / EHS-WC-HA223-75 / Adj B-223 **Collected:** 6/2/2022 5:40:00 AM **Lab ID:** 012208791-0070

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.66	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:25

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012208791

CustomerID: TTIE54

CustomerPO: 034933

ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 77 / EHS-WC-HLRR-77 / By Library Rest **Collected:** 6/2/2022 5:44:00 AM **Lab ID:** 012208791-0071

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:26

Client Sample Description 78 / EHS-WC-HLRR-78 / By Library Rest **Collected:** 6/2/2022 5:44:00 AM **Lab ID:** 012208791-0072

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:31

Client Sample Description 79 / EHS-WC-HF216-79 / Adj F-216 **Collected:** 6/2/2022 5:49:00 AM **Lab ID:** 012208791-0073

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.88	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:32

Client Sample Description 80 / EHS-WC-HF216-80 / Adj F-216 **Collected:** 6/2/2022 5:49:00 AM **Lab ID:** 012208791-0074

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:34

Client Sample Description 81 / EHS-IM-FH-81 / Field House **Collected:** 6/2/2022 5:52:00 AM **Lab ID:** 012208791-0075

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012208791

CustomerID: TTIE54

CustomerPO: 034933

ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 6/2/2022 09:45 AM

Project: 22-411 Egg Harbor - High School

Analytical Results

Client Sample Description 82 / EHS-SF-FH-82 / Field House **Collected:** 6/2/2022 5:53:00 AM **Lab ID:** 012208791-0076

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.0	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:43

Client Sample Description 84 / EHS-IM-FH-84 / Field House **Collected:** 6/2/2022 5:57:00 AM **Lab ID:** 012208791-0077

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:45

Client Sample Description 85 / EHS-SF-C128-85 / C128 **Collected:** 6/2/2022 5:17:00 AM **Lab ID:** 012208791-0078

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/15/2022 VD	6/15/2022 VD 20:46

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results