



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Nathanael Roberts  
TTI Environmental Inc.  
1253 North Church Street  
Moorestown, NJ 08057**

6/22/2022

Phone: (856) 840-8800  
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/3/2022. The results are tabulated on the attached data pages for the following client designated project:

**22-411 Egg Harbor - Swift School**

The reference number for these samples is EMSL Order #012209063. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012209063  
 CustomerID: TTIE54  
 CustomerPO: 034933  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 6/3/2022 11:25 AM

Project: 22-411 Egg Harbor - Swift School

**Analytical Results**

**Client Sample Description** DPP-SF-MO-1 Main Office **Collected:** 6/3/2022 **Lab ID:** 012209063-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.07	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:21

**Client Sample Description** DPP-WF-HFAC-2 Outside Faculty Room **Collected:** 6/3/2022 **Lab ID:** 012209063-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.85	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:26

**Client Sample Description** DPP-SF-FAC-3 Faculty Room **Collected:** 6/3/2022 **Lab ID:** 012209063-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.96	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:27

**Client Sample Description** DPP-WC-H25-4 By Room 25 **Collected:** 6/3/2022 **Lab ID:** 012209063-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:29

**Client Sample Description** DPP-WF-H18-5 By Room 18 **Collected:** 6/3/2022 **Lab ID:** 012209063-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	12.2	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012209063  
 CustomerID: TTIE54  
 CustomerPO: 034933  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 6/3/2022 11:25 AM

Project: 22-411 Egg Harbor - Swift School

**Analytical Results**

**Client Sample Description** DPP-WF-H23-6 By Room 23 **Collected:** 6/3/2022 **Lab ID:** 012209063-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	10.5	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:35

**Client Sample Description** DPP-WC-HGYM-8 Outside Gym **Collected:** 6/3/2022 **Lab ID:** 012209063-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:37

**Client Sample Description** DPP-WC-HGYM-9 Outside Gym **Collected:** 6/3/2022 **Lab ID:** 012209063-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:38

**Client Sample Description** DPP-BF-HGYM-10 Outside Gym **Collected:** 6/3/2022 **Lab ID:** 012209063-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:40

**Client Sample Description** D99-SF-NRS-11 Nurse **Collected:** 6/3/2022 **Lab ID:** 012209063-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.01	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012209063  
 CustomerID: TTIE54  
 CustomerPO: 034933  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 6/3/2022 11:25 AM

Project: 22-411 Egg Harbor - Swift School

**Analytical Results**

**Client Sample Description** DPP-SF-NBR-12 Nurse Break Room **Collected:** 6/3/2022 **Lab ID:** 012209063-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	5.73	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:43

**Client Sample Description** DPP-SF-LBR-13 Library Break Room **Collected:** 6/3/2022 **Lab ID:** 012209063-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	10.6	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:47

**Client Sample Description** DPP-SF-KIT-14 Kitchen **Collected:** 6/3/2022 **Lab ID:** 012209063-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.68	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:49

**Client Sample Description** DPP-SF-KIT-15 Kitchen **Collected:** 6/3/2022 **Lab ID:** 012209063-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	62.0	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:57

**Client Sample Description** DPP-SF-KIT-16 Kitchen **Collected:** 6/3/2022 **Lab ID:** 012209063-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	22.6	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:58

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012209063  
 CustomerID: TTIE54  
 CustomerPO: 034933  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 6/3/2022 11:25 AM

Project: 22-411 Egg Harbor - Swift School

**Analytical Results**

**Client Sample Description** DPP-SF-CPY-17 Copy Room By Kitchen **Collected:** 6/3/2022 **Lab ID:** 012209063-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	10.2	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 06:00

**Client Sample Description** DPP-WC-H11-18 By Room 11 **Collected:** 6/3/2022 **Lab ID:** 012209063-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 06:01

**Client Sample Description** DPP-BF-H11-19 By Room 11 **Collected:** 6/3/2022 **Lab ID:** 012209063-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 06:03

**Client Sample Description** DPP-SB-R54-21 Room 54 **Collected:** 6/3/2022 **Lab ID:** 012209063-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.13	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 06:05

**Client Sample Description** DPP-SB-R50-22 Room 53 **Collected:** 6/3/2022 **Lab ID:** 012209063-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.76	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 06:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012209063  
 CustomerID: TTIE54  
 CustomerPO: 034933  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 6/3/2022 11:25 AM

Project: 22-411 Egg Harbor - Swift School

**Analytical Results**

**Client Sample Description** DPP-SB-R50-23 Room 50 **Collected:** 6/3/2022 **Lab ID:** 012209063-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	7.92	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:31

**Client Sample Description** DPP-SB-R51-24 Room 51 **Collected:** 6/3/2022 **Lab ID:** 012209063-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	7.64	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:39

**Client Sample Description** DPP-SB-R65-25 Room 65 **Collected:** 6/3/2022 **Lab ID:** 012209063-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	8.94	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:40

**Client Sample Description** DPP-SB-R64-26 Room 64 **Collected:** 6/3/2022 **Lab ID:** 012209063-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.59	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:42

**Client Sample Description** DPP-SB-R56-27 Room 56 **Collected:** 6/3/2022 **Lab ID:** 012209063-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.86	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:44

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012209063  
 CustomerID: TTIE54  
 CustomerPO: 034933  
 ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 6/3/2022 11:25 AM

Project: 22-411 Egg Harbor - Swift School

**Analytical Results**

**Client Sample Description** DPP-SB-R57-28 Room 57 **Collected:** 6/3/2022 **Lab ID:** 012209063-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.26	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:45

**Client Sample Description** DPP-SB-R63-29 Room 63 **Collected:** 6/3/2022 **Lab ID:** 012209063-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.25	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:47

**Client Sample Description** DPP-SB-R62-30 Room 62 **Collected:** 6/3/2022 **Lab ID:** 012209063-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.74	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:48

**Client Sample Description** DPP-SB-R61-31 Room 61 **Collected:** 6/3/2022 **Lab ID:** 012209063-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.73	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:50

**Client Sample Description** DPP-SB-R60-32 Room 60 **Collected:** 6/3/2022 **Lab ID:** 012209063-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	16.0	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:51

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012209063

CustomerID: TTIE54

CustomerPO: 034933

ProjectID:

Attn: **Nathanael Roberts**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 6/3/2022 11:25 AM

Project: 22-411 Egg Harbor - Swift School

**Analytical Results**

**Client Sample Description** DPP-SB-R59-33 Room 59 **Collected:** 6/3/2022 **Lab ID:** 012209063-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	6.79	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 04:53

**Client Sample Description** DPP-SB-R58-34 Room 58 **Collected:** 6/3/2022 **Lab ID:** 012209063-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.96	1.00 µg/L	6/20/2022 VD	6/21/2022 VD 05:01

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results